

McGill's Well Service and Supply Ltd
Cumberland BC
250 338 1661
Email: wellguy@telus.net

On site water level testing in drilled wells.

Site Location: Greig Seafood, #1 Mill Road. Gold River.
Date: November 23 2022

Well#3

Water level with pump running=26 FT from top of concrete.
Shaft driven turbine pump.

Well#6

Static water level pump not running=18.1FT
Shaft driven turbine pump.

Well#4

Static water level pump not running=12.68FT
Submersible pump in well.

Well#7

Water level with pump running=14 FT from top of concrete.
Salt water well.
Submersible pump in well.

Well#5

Water level with pump running=24.27 FT from top of concrete.
Shaft driven turbine pump.

Ian McGill

Certified well pump Installer.
Certified and bonded electrical contractor.
Member of BC Ground Water Association
Associates degree in Applied Science