

CCC Certificate · China

China Compulsory Certificate

ELG-200-24DA

available on request

molo design, ltd.

1470 Venables Street
Vancouver BC
Canada V5L 2G7

t +1 604 685 0340

info@molodesign.com
www.molodesign.com





中国国家强制性产品认证证书

证书编号: 2016011002884437

发证日期: 2022年08月29日

有效期至: 2026年05月17日

**认证委托人名称
及注册地址** 明纬(广州)电子有限公司
广州市花都区金谷南路11号

**产品生产者名称
及注册地址** 明纬企业股份有限公司
新北市五股区五权三路28号

**生产企业名称
及生产地址** 明纬(广州)电子有限公司
广州市花都区金谷南路11号

**产品名称和系列、
规格、型号** LED模块用交流电子控制装置(LED控制装置,独立式,恒压/恒流模式,安全特低电压,ta:50°C,tc:90°C,
I类,IP67,适宜直接安装在普通可燃材料表面,定温热保护:110°C,不可调光)
见附件。100-240V~50/60Hz.

**产品标准和
技术要求** GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

上述产品符合 CNCA-C10-01:2014 认证规则的要求,特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期:2016年07月26日

经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



签发:

谢肇煦



中国质量认证中心





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016011002884437

Valid from: Aug.29,2022

Valid until: May.17,2026

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
No.11 Jingu South Road, Huadu District, Guangzhou, China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

MEAN WELL Enterprises Co.,Ltd.
No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan

**NAME AND LOCATION
OF THE FACTORY**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
No.11 Jingu South Road,Huadu District, Guangzhou, China

PRODUCT MODEL(S)

A.C. Supplied Electronic Controlgear For LED Modules (Independent, Constant Voltage/Constant Current Mode, SELV, ta:50°C, tc:90°C, Class I, IP67, Suitable For Direct Mounting On Normally Flammable Material, Temperature Declared Thermally Protected: 110°C, Non-Dimmable)
See Appendix. 100-240V ~ 50/60Hz.

**STANDARDS AND
TECHNICAL REQUIREMENTS**

GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jul.26,2016

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





中国国家强制性产品认证证书

证书编号: 2016011002884437

第1页 共1页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 3075726

序号 产品型号 参数 备注

- 1 ELG-200-12 输出 (当输入电压: 100-200Vac): 12Vdc, 12A (恒压恒流), 配套光源: 144W LED 模块;
输出 (当输入电压: 200-240Vac): 12Vdc, 16A (恒压恒流), 配套光源: 192W LED 模块 —
- 2 ELG-200-24 输出 (当输入电压: 100-200Vac): 24Vdc, 6.25A (恒压恒流), 配套光源: 150W LED 模块;
输出 (当输入电压: 200-240Vac): 24Vdc, 8.4A (恒压恒流), 配套光源: 201.6W LED 模块—
- 3 ELG-200-36 输出 (当输入电压: 100-200Vac): 36Vdc, 4.16A (恒压恒流), 配套光源: 149.76W LED 模块;
输出 (当输入电压: 200-240Vac): 36Vdc, 5.55A (恒压恒流), 配套光源: 199.8W LED 模块 —
- 4 ELG-200-42 输出 (当输入电压: 100-200Vac): 42Vdc, 3.57A (恒压恒流), 配套光源: 149.94W LED 模块;
输出 (当输入电压: 200-240Vac): 42Vdc, 4.76A (恒压恒流), 配套光源: 199.9W LED 模块 —
- 5 ELG-200-48 输出 (当输入电压: 100-200Vac): 48Vdc, 3.12A (恒压恒流), 配套光源: 149.76W LED 模块;
输出 (当输入电压: 200-240Vac): 48Vdc, 4.16A (恒压恒流), 配套光源: 199.68W LED 模块 —
- 6 ELG-200-54 输出 (当输入电压: 100-200Vac): 54Vdc, 2.78A (恒压恒流), 配套光源: 150.12W LED 模块;
输出 (当输入电压: 200-240Vac): 54Vdc, 3.72A (恒压恒流), 配套光源: 200.88W LED 模块 —
- 7 ELG-240-24 输出 (当输入电压: 100-200Vac): 24Vdc, 7.5A (恒压恒流), 配套光源: 180W LED 模块;
输出 (当输入电压: 200-240Vac): 24Vdc, 10A (恒压恒流), 配套光源: 240W LED 模块 —
- 8 ELG-240-36 输出 (当输入电压: 100-200Vac): 36Vdc, 5A (恒压恒流), 配套光源: 180W LED 模块;
输出 (当输入电压: 200-240Vac): 36Vdc, 6.66A (恒压恒流), 配套光源: 239.76W LED 模块 —
- 9 ELG-240-42 输出 (当输入电压: 100-200Vac): 42Vdc, 4.28A (恒压恒流), 配套光源: 179.76W LED 模块;
输出 (当输入电压: 200-240Vac): 42Vdc, 5.71A (恒压恒流), 配套光源: 239.82W LED 模块 —
- 10 ELG-240-48 输出 (当输入电压: 100-200Vac): 48Vdc, 3.75A (恒压恒流), 配套光源: 180W LED 模块;
输出 (当输入电压: 200-240Vac): 48Vdc, 5.0A (恒压恒流), 配套光源: 240W LED 模块 —
- 11 ELG-240-54 输出 (当输入电压: 100-200Vac): 54Vdc, 3.34A (恒压恒流), 配套光源: 180.36W LED 模块;
输出 (当输入电压: 200-240Vac): 54Vdc, 4.45A (恒压恒流), 配套光源: 240.3W LED 模块 —
- 输入: 100-240V~, 50/60Hz



中国质量认证中心





中国国家强制性产品认证证书

证书编号: 2016011002890090

发证日期: 2022年08月29日

有效期至: 2026年05月17日

认证委托人名称 明纬(广州)电子有限公司
及注册地址 广州市花都区金谷南路11号

产品生产者名称 明纬企业股份有限公司
及注册地址 新北市五股区五权三路28号

生产企业名称 明纬(广州)电子有限公司
及生产地址 广州市花都区金谷南路11号

产品名称和系列、规格、型号 LED模块用交流电子控制装置(LED控制装置,独立式,恒压/恒流模式,安全特低电压,ta:50°C,tc:90°C, I类, IP65, 适宜直接安装在普通可燃材料表面, 定温热保护: 110°C, 不可调光) 见附件。100-240V~ 50/60Hz

产品标准和技术要求 GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

上述产品符合 CNCA-C10-01:2014 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年08月09日

经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发:

谢肇煦



中国质量认证中心





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016011002890090

Valid from: Aug.29,2022

Valid until: May.17,2026

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
No.11 Jingu South Road, Huadu District, Guangzhou, China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

MEAN WELL Enterprises Co.,Ltd.
No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan

**NAME AND LOCATION
OF THE FACTORY**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
No.11 Jingu South Road,Huadu District, Guangzhou, China

PRODUCT MODEL(S)

A.C. Supplied Electronic Controlgear For LED Modules (Independent, Constant Voltage/Constant
Current Mode, SELV, ta:50°C, tc:90°C, Class I, IP65, Suitable For Direct Mounting On Normally
Flammable Material, Temperature Declared Thermally Protected: 110°C, Non-Dimmable)
See Appendix. 100-240V ~ 50/60Hz

**STANDARDS AND
TECHNICAL REQUIREMENTS**

GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory
certification(REFNO. CNCA-C10-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry
date.

Date of original issued: Aug.09,2016

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2016011002890090

纸 号: 3075729

序号	产品型号	参数	备注
1	ELG-200-12A	输出 (当输入电压: 100-200Vac): 12Vdc, 12A (恒压恒流), 配套光源: 144W LED 模块; 输出 (当输入电压: 200-240Vac): 12Vdc, 16A (恒压恒流), 配套光源: 192W LED 模块	—
2	ELG-200-24A	输出 (当输入电压: 100-200Vac): 24Vdc, 6.25A (恒压恒流), 配套光源: 150W LED 模块; 输出 (当输入电压: 200-240Vac): 24Vdc, 8.4A (恒压恒流), 配套光源: 201.6W LED 模块	—
3	ELG-200-36A	输出 (当输入电压: 100-200Vac): 36Vdc, 4.16A (恒压恒流), 配套光源: 149.76W LED 模块; 输出 (当输入电压: 200-240Vac): 36Vdc, 5.55A (恒压恒流), 配套光源: 199.8W LED 模块	—
4	ELG-200-42A	输出 (当输入电压: 100-200Vac): 42Vdc, 3.57A (恒压恒流), 配套光源: 149.94W LED 模块; 输出 (当输入电压: 200-240Vac): 42Vdc, 4.76A (恒压恒流), 配套光源: 199.9W LED 模块	—
5	ELG-200-48A	输出 (当输入电压: 100-200Vac): 48Vdc, 3.12A (恒压恒流), 配套光源: 149.76W LED 模块; 输出 (当输入电压: 200-240Vac): 48Vdc, 4.16A (恒压恒流), 配套光源: 199.68W LED 模块	—
6	ELG-200-54A	输出 (当输入电压: 100-200Vac): 54Vdc, 2.78A (恒压恒流), 配套光源: 150.12W LED 模块; 输出 (当输入电压: 200-240Vac): 54Vdc, 3.72A (恒压恒流), 配套光源: 200.88W LED 模块	—

注: 此附录与证书同时使用时有效。



中国质量认证中心





中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2016011002890090

纸 号: 3075729

7	ELG-240-24A	输出 (当输入电压: 100-200Vac): 24Vdc, 7.5A (恒压恒流), 配套光源: 180W LED 模块; 输出 (当输入电压: 200-240Vac): 24Vdc, 10A (恒压恒流), 配套光源: 240W LED 模块	—
9	ELG-240-36A	输出 (当输入电压: 100-200Vac): 36Vdc, 5A (恒压恒流), 配套光源: 180W LED 模块; 输出 (当输入电压: 200-240Vac): 36Vdc, 6.66A (恒压恒流), 配套光源: 239.76W LED 模块	—
10	ELG-240-42A	输出 (当输入电压: 100-200Vac): 42Vdc, 4.28A (恒压恒流), 配套光源: 179.76W LED 模块; 输出 (当输入电压: 200-240Vac): 42Vdc, 5.71A (恒压恒流), 配套光源: 239.82W LED 模块	—
11	ELG-240-48A	输出 (当输入电压: 100-200Vac): 48Vdc, 3.75A (恒压恒流), 配套光源: 180W LED 模块; 输出 (当输入电压: 200-240Vac): 48Vdc, 5.0A (恒压恒流), 配套光源: 240W LED 模块	—
12	ELG-240-54A	输出 (当输入电压100-200V~时): 54Vdc, 3.34A (恒压恒流), 配套光源: 180.36W LED 模块; 输出 (当输入电压200-240V~时): 54Vdc, 4.45A (恒流), 配套光源: 240.3W LED 模块	—
输入: 100-240V~, 50/60Hz			

注: 此附录与证书同时使用时有效。



中国质量认证中心





中国国家强制性产品认证证书

证书编号: 2016011002889174

发证日期: 2022年08月29日

有效期至: 2026年05月17日

认证委托人名称 明纬(广州)电子有限公司
及注册地址 广州市花都区金谷南路11号

产品生产者名称 明纬企业股份有限公司
及注册地址 新北市五股区五权三路28号

生产企业名称 明纬(广州)电子有限公司
及生产地址 广州市花都区金谷南路11号

产品名称和系列、规格、型号 LED 模块用交流电子控制装置(LED控制装置, 独立式, 恒流模式, 安全特低电压, ta:50°C, tc:90°C, I类, IP67, 适宜直接安装在普通可燃材料表面, 定温热保护: 110°C, 部分型号控制端口调光) 见附件。100-240V~ 50/60Hz

产品标准和技术要求 GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

上述产品符合 CNCA-C10-01:2014 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年08月09日

经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发:

谢肇煦



中国质量认证中心





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016011002889174

Valid from: Aug.29,2022

Valid until: May.17,2026

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
No.11 Jingu South Road, Huadu District, Guangzhou, China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

MEAN WELL Enterprises Co.,Ltd.
No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan

**NAME AND LOCATION
OF THE FACTORY**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
No.11 Jingu South Road,Huadu District, Guangzhou, China

PRODUCT MODEL(S)

A.C. Supplied Electronic Controlgear For LED Modules (Independent, Constant Current Mode, SELV,
ta:50°C, tc:90°C, Class I, IP67, Suitable For Direct Mounting On Normally Flammable Material,
Temperature Declared Thermally Protected: 110°C, Controlled Port Dimming For Some Type)
See Appendix. 100-240V ~ 50/60Hz

**STANDARDS AND
TECHNICAL REQUIREMENTS**

GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Aug.09,2016

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





中国国家强制性产品认证证书

附 录

第 1 页 共 4 页

证书编号: 2016011002889174

纸 号: 3075728

序号	产品型号	参数	备注
1	ELG-200-12B	输出: Max. 12Vdc, 12A (恒流), 配套光源: 144W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 12Vdc, 16A (恒流), 配套光源: 192W LED 模块 (当输入电压: 200-240Vac)	B 型调光
2	ELG-200-12D		D 型调光
3	ELG-200-12D2		D2 型调光
4	ELG-200-12DA		DA 型调光
5	ELG-200-24B	输出: Max. 24Vdc, 6.25A (恒流), 配套光源: 150W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 24Vdc, 8.4A (恒流), 配套光源: 201.6W LED 模块 (当输入电压: 200-240Vac)	B 型调光
6	ELG-200-24D		D 型调光
7	ELG-200-24D2		D2 型调光
8	ELG-200-24DA		DA 型调光
9	ELG-200-36B	输出: Max. 36Vdc, 4.16A (恒流), 配套光源: 149.76W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 36Vdc, 5.55A (恒流), 配套光源: 199.8W LED 模块 (当输入电压: 200-240Vac)	B 型调光
10	ELG-200-36D		D 型调光
11	ELG-200-36D2		D2 型调光
12	ELG-200-36DA		DA 型调光

注: 此附录与证书同时使用时有效。



中国质量认证中心





中国国家强制性产品认证证书

附 录

证书编号: 2016011002889174

第 2 页 共 4 页

纸 号: 3075728

13	ELG-200-42B	输出: Max. 42Vdc, 3.57A(恒流), 配套光源: 149.94W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 42Vdc, 4.76A(恒流), 配套光源: 199.9W LED 模块 (当输入电压: 200-240Vac)	B 型调光
14	ELG-200-42D		D 型调光
15	ELG-200-42D2		D2 型调光
16	ELG-200-42DA		DA 型调光
17	ELG-200-48B	输出: Max. 48Vdc, 3.12A(恒流), 配套光源: 149.76W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 48Vdc, 4.16A(恒流), 配套光源: 199.68W LED 模块 (当输入电压: 200-240Vac)	B 型调光
18	ELG-200-48D		D 型调光
19	ELG-200-48D2		D2 型调光
20	ELG-200-48DA		DA 型调光
21	ELG-200-54B	输出: Max. 54Vdc, 2.78A(恒流), 配套光源: 150.12W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 54Vdc, 3.72A(恒流), 配套光源: 200.88W LED 模块 (当输入电压: 200-240Vac)	B 型调光
22	ELG-200-54D		D 型调光
23	ELG-200-54D2		D2 型调光
24	ELG-200-54DA		DA 型调光
25	ELG-240-24B	输出: Max. 24Vdc, 7.5A (恒流), 配套光源: 180W LED 模块 (当输入电压: 100-200Vac);	B 型调光

注: 此附录与证书同时使用时有效。



中国质量认证中心





中国国家强制性产品认证证书

附 录

证书编号: 2016011002889174

第 3 页 共 4 页

纸 号: 3075728

26	ELG-240-24D	输出: Max. 24Vdc, 10A (恒流), 配套光源: 240W LED 模块 (当输入电压: 200-240Vac)	D 型调光
27	ELG-240-24D2		D2 型调光
28	ELG-240-24DA		DA 型调光
29	ELG-240-36B	输出: Max. 36Vdc, 5A (恒流), 配套光源: 180W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 36Vdc, 6.66A (恒流), 配套光源: 239.76W LED 模块 (当输入电压: 200-240Vac)	B 型调光
30	ELG-240-36D		D 型调光
31	ELG-240-36D2		D2 型调光
32	ELG-240-36DA		DA 型调光
33	ELG-240-42B	输出: Max. 42Vdc, 4.28A (恒流), 配套光源: 179.76W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 42Vdc, 5.71A (恒流), 配套光源: 239.82W LED 模块 (当输入电压: 200-240Vac)	B 型调光
34	ELG-240-42D		D 型调光
35	ELG-240-42D2		D2 型调光
36	ELG-240-42DA		DA 型调光
37	ELG-240-48B	输出: Max. 48Vdc, 3.75A (恒流), 配套光源: 180W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 48Vdc, 5.0A (恒流), 配套光源: 240W LED 模块 (当输入电压: 200-240Vac)	B 型调光
38	ELG-240-48D		D 型调光

注: 此附录与证书同时使用时有效。



中国质量认证中心





中国国家强制性产品认证证书

附 录

证书编号: 2016011002889174

第 4 页 共 4 页

纸 号: 3075728

39	ELG-240-48D2		D2 型调光
40	ELG-240-48DA		DA 型调光
41	ELG-240-54B	输出: Max. 54Vdc, 3.34A(恒流), 配套光源: 180.36W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 54Vdc, 4.45A(恒流), 配套光源: 240.3W LED 模块 (当输入电压: 200-240Vac)	B 型调光
42	ELG-240-54D		D 型调光
43	ELG-240-54D2		D2 型调光
44	ELG-240-54DA		DA 型调光

输入: 100-240V~, 50/60Hz

备注: 以上型号在正常工作状态下, 实测输入功率均大于25W。

调光类型:

1. B 型调光方式: 外接电阻调光;
2. D 型调光方式: 定时芯片调光, 在规定的时间内, 调整输出功率; 非控制端口调光
3. D2 型调光方式: 可编程定时调光, 使用者可根据需要, 通过编程线修改定时调光的时间长短和降载幅度; 非控制端口调光
4. DA 型调光方式: DALI 功能调光。

注: 此附录与证书同时使用时有效。



中国质量认证中心





中国国家强制性产品认证证书

证书编号: 2016011002888991

发证日期: 2022年08月29日

有效期至: 2026年05月17日

认证委托人名称 明纬(广州)电子有限公司
及注册地址 广州市花都区金谷南路11号

产品生产者名称 明纬企业股份有限公司
及注册地址 新北市五股区五权三路28号

生产企业名称 明纬(广州)电子有限公司
及生产地址 广州市花都区金谷南路11号

产品名称和系列、规格、型号 LED 模块用交流电子控制装置(LED 控制装置, 独立式, 恒流模式, 安全特低电压, ta:50°C, tc:90°C, I 类, IP65, 适宜直接安装在普通可燃材料表面, 定温热保护: 110°C, 部分型号控制端口调光) 见附件。100-240V ~ 50/60Hz

产品标准和技术要求 GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

上述产品符合 CNCA-C10-01:2014 认证规则的要求, 特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
本证书为变更证书, 证书首次颁发日期: 2016 年 08 月 09 日
经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发:

谢肇煦



中国质量认证中心





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016011002888991

Valid from: Aug.29,2022

Valid until: May.17,2026

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
No.11 Jingu South Road, Huadu District, Guangzhou, China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

MEAN WELL Enterprises Co.,Ltd.
No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan

**NAME AND LOCATION
OF THE FACTORY**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
No.11 Jingu South Road,Huadu District, Guangzhou, China

PRODUCT MODEL(S)

A.C. Supplied Electronic Controlgear For LED Modules (Independent, Constant Current Mode, SELV,
ta:50°C, tc:90°C, Class I, IP65, Suitable For Direct Mounting On Normally Flammable Material,
Temperature Declared Thermally Protected: 110°C, Controlled Port Dimming For Some Type)
See Appendix. 100-240V ~ 50/60Hz

**STANDARDS AND
TECHNICAL REQUIREMENTS**

GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Aug.09,2016

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





中国国家强制性产品认证证书

附 录

证书编号: 2016011002888991

第 1 页 共 3 页

纸 号: 3075727

序号	产品型号	参数	备注
1	ELG-200-12AB	输出: Max. 12Vdc, 12A (恒流), 配套光源: 144W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 12Vdc, 16A (恒流), 配套光源: 192W LED 模块 (当输入电压: 200-240Vac)	B 型调光
2	ELG-200-12AD2		D2 型调光
3	ELG-200-12ADA		DA 型调光
4	ELG-200-24AB	输出: Max. 24Vdc, 6.25A (恒流), 配套光源: 150W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 24Vdc, 8.4A (恒流), 配套光源: 201.6W LED 模块 (当输入电压: 200-240Vac)	B 型调光
5	ELG-200-24AD2		D2 型调光
6	ELG-200-24ADA		DA 型调光
7	ELG-200-36AB	输出: Max. 36Vdc, 4.16A (恒流), 配套光源: 149.76W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 36Vdc, 5.55A (恒流), 配套光源: 199.8W LED 模块 (当输入电压: 200-240Vac)	B 型调光
8	ELG-200-36AD2		D2 型调光
9	ELG-200-36ADA		DA 型调光
10	ELG-200-42AB	输出: Max. 42Vdc, 3.57A (恒流), 配套光源: 149.94W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 42Vdc, 4.76A (恒流), 配套光源: 199.9W LED 模块 (当输入电压: 200-240Vac)	B 型调光
11	ELG-200-42AD2		D2 型调光
12	ELG-200-42ADA		DA 型调光

注: 此附录与证书同时使用时有效。



中国质量认证中心





中国国家强制性产品认证证书

附 录

证书编号: 2016011002888991

第 2 页 共 3 页

纸 号: 3075727

13	ELG-200-48AB	输出: Max. 48Vdc, 3.12A(恒流), 配套光源: 149.76W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 48Vdc, 4.16A(恒流), 配套光源: 199.68W LED 模块 (当输入电压: 200-240Vac)	B 型调光
14	ELG-200-48AD2		D2 型调光
15	ELG-200-48ADA		DA 型调光
16	ELG-200-54AB	输出: Max. 54Vdc, 2.78A(恒流), 配套光源: 150.12W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 54Vdc, 3.72A(恒流), 配套光源: 200.88W LED 模块 (当输入电压: 200-240Vac)	B 型调光
17	ELG-200-54AD2		D2 型调光
18	ELG-200-54ADA		DA 型调光
19	ELG-240-24AB	输出: Max. 24Vdc, 7.5A (恒流), 配套光源: 180W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 24Vdc, 10A (恒流), 配套光源: 240W LED 模块 (当输入电压: 200-240Vac)	B 型调光
20	ELG-240-24AD2		D2 型调光
21	ELG-240-24ADA		DA 型调光
22	ELG-240-36AB	输出: Max. 36Vdc, 5A (恒流), 配套光源: 180W LED 模块 (当输入电压: 100-200Vac); 输出: Max. 36Vdc, 6.66A(恒流), 配套光源: 239.76W LED 模块 (当输入电压: 200-240Vac)	B 型调光
23	ELG-240-36AD2		D2 型调光
24	ELG-240-36ADA		DA 型调光
25	ELG-240-42AB	输出: Max. 42Vdc, 4.28A(恒流), 配套光源: 179.76W	B 型调光

注: 此附录与证书同时使用时有效。



中国质量认证中心





中国国家强制性产品认证证书

附 录

第 3 页 共 3 页

证书编号: 2016011002888991

纸 号: 3075727

26	ELG-240-42AD2	LED 模块 (当输入电压: 100-200Vac); 输出: Max. 42Vdc, 5.71A (恒流), 配套光源: 239.82W	D2 型调光
27	ELG-240-42ADA	LED 模块 (当输入电压: 200-240Vac)	DA 型调光
28	ELG-240-48AB	输出: Max. 48Vdc, 3.75A (恒流), 配套光源: 180W	B 型调光
29	ELG-240-48AD2	LED 模块 (当输入电压: 100-200Vac); 输出: Max. 48Vdc, 5.0A (恒流), 配套光源: 240W	D2 型调光
30	ELG-240-48ADA	LED 模块 (当输入电压: 200-240Vac)	DA 型调光
31	ELG-240-54AB	输出: Max. 54Vdc, 3.34A (恒流), 配套光源: 180.36W	B 型调光
32	ELG-240-54AD2	LED 模块 (当输入电压: 100-200Vac); 输出: Max. 54Vdc, 4.45A (恒流), 配套光源: 240.3W	D2 型调光
33	ELG-240-54ADA	LED 模块 (当输入电压: 200-240Vac)	DA 型调光

输入: 100-240V~, 50/60Hz

备注: 以上型号在正常工作状态下, 实测输入功率均大于25W。

调光类型:

1. B 型调光方式: 外接电阻调光;
2. D2 型调光方式: 可编程定时调光, 使用者可根据需要, 通过编程线修改定时调光的时间长短和降载幅度; 非控制端口调光
3. DA 型调光方式: DALI 功能调光。

注: 此附录与证书同时使用时有效。



中国质量认证中心

